

FEATURES

- 4 configurable outputs: fan coil, shutter channels (up to 2) and individual outputs (up to 4)
- Outputs suitable for capacitive loads, maximum 140 µF
- 5 analog/digital inputs
- Manual output operation with push button and LED status indicator
- 10 logic functions
- Output timing
- 4 thermostats
- Total data saving on KNX bus failure
- Integrated KNX BCU (TP1-256)
- Dimensions 67 x 90 x 36 mm (2 DIN units)
- DIN rail mounting according to IEC 60715 TH35, with fixing clamp
- Possibility of connecting different phases in adjacent outputs
- Conformity with the CE, UKCA, RCM directives (marks on the right side)




Figure 1: MINiBOX 45 v2

1. Analog/Digital inputs	2. Outputs	3. Output status LED indicator	4. Output control button
5. Programming/test LED	6. Programming/test button	7. KNX Connector	8. Fixing clamp

Programming/Test button: short press to set programming mode. If this button is held while plugging the device into the KNX bus, it enters the safe mode. If this button is held for more than 3 seconds, the device enters the test mode.

Programming/Test LED: programming mode indicator (red). When the device enters the safe mode, it blinks (red) every half second. The manual mode is indicated by the green color. During the start-up (reset or after KNX bus failure) and if the device is not in safe mode, it starts a blue blinking sequence.

GENERAL SPECIFICATIONS		CONCEPT		DESCRIPTION	
Type of device		Electric operation control device			
KNX supply	Voltage (typical)		29 VDC SELV		
	Voltage range		21-31 VDC		
	Maximum consumption	Voltage		mA	mW
		29 VDC (typical)		4.9	142.1
24 VDC ¹		10	240		
Connection type		Typical TP1 bus connector for 0.8 mm Ø rigid cable			
External power supply		Not required			
Operation temperature		0 .. +55 °C			
Storage temperature		-20 .. +55 °C			
Operation humidity		5 .. 95%			
Storage humidity		5 .. 95%			
Complementary characteristics		Class B			
Protection class / Overvoltage category		II / III (4000 V)			
Operation type		Continuous operation			
Device action type		Type 1			
Electrical stress period		Long			
Degree of protection / Pollution degree		IP20 / 2 (clean environment)			
Installation		Independent device to be mounted inside electrical panels with DIN rail (IEC 60715)			
Minimum clearances		Not required			
Response on KNX bus failure		Data saving according to parameterization			
Response on KNX bus restart		Data recovery according to parameterization			
Operation indicator		The programming LED indicates programming mode (red) and test mode (green). Each output LED indicates its status			
Weight		97 g			
PCB CTI index		175 V			
Housing material / Ball pressure test temperature		PC FR V0 halogen free / 75 °C (housing) - 125 °C (connectors)			

¹ Maximum consumption in the worst-case scenario (KNX Fan-In model).

OUTPUTS SPECIFICATIONS AND CONNECTIONS		
CONCEPT	DESCRIPTION	
Number of outputs	4	
Output type / Disconnection type	Potential-free outputs through bistable relays with tungsten pre-contact / Micro-disconnection	
Rated current per output	AC 16(6) A @ 250 VAC (4000 VA) DC 7 A @ 30 VDC (210 W)	
Maximum load per output	Resistive	4000 W
	Inductive	1500 VA
Maximum inrush current	800 A/200 µs 165 A/20 ms	
Connections in adjacent outputs	Possibility of connecting different phases. It is not allowed to connect power supplies of different order, SELV with NO SELV, in the same block	
Total maximum current in device	40 A	
Short-circuit protection	NO	
Overload protection	NO	
Connection method	Screw terminal block (0.5 Nm max.)	
Cable cross-section	0.5-4 mm ² (IEC) / 20-12 AWG (UL)	
Outputs per common	1	
Maximum response time	10 ms	
Mechanical lifetime (min. cycles)	3 000 000	
Electrical lifetime (min. cycles) ¹	100000 @ 8 A / 25000 @ 16 A (VAC)	

¹ Lifetime values could change depending on the load type.


INPUTS SPECIFICATIONS AND CONNECTIONS		
CONCEPT	DESCRIPTION	
Number of inputs	5	
Inputs per common	1	
Operation voltage	+3.3 VDC in the common	
Operation current	1 mA @ 3.3 VDC (per input)	
Switching type	Dry voltage contacts between input and common	
Connection method	Screw terminal block (0.4 Nm max.)	
Cable cross-section	0.5-2.5 mm ² (IEC) / 26-12 AWG (UL)	
Maximum cable length	30 m	
NTC probe length	1.5 m (extensible up to 30 m)	
NTC accuracy (@ 25 °C) ²	±0.5 °C	
Temperature resolution	0.1 °C	
Maximum response time	10 ms	

² For Zennio temperature probes.

INPUTS CONNECTION


Any combination of the following accessories is allowed in the inputs:

Temperature Probe**



⚠ Commons of different devices must not be connected together.


Motion Sensor



* In case of using ZN110-DETEC-P sensor, its micro switch number 2 must be in **Type B position**.

** Zennio temperature probe or any NTC with known resistance values at three points in the range [-55, 150 °C].

Switch/Sensor/ Push button



WIRING DIAGRAMS






Figure 2: Wiring example (from left to right, and up to down): 2 loads, 2 loads connected to different phases, shutter and fan coil

⚠ In order to ensure the expected status of the relays, please check that the device is connected to the KNX bus before energizing the power circuit.

Attaching MINiBOX 45 v2 to DIN rail:



Removing MINiBOX 45 v2 from DIN rail:



SAFETY INSTRUCTIONS AND ADDITIONAL NOTES

- Installation should only be performed by qualified professionals according to the laws and regulations applicable in each country.
- Do not connect the mains voltage nor any other external voltage to any point of the KNX bus; it would represent a risk for the entire KNX system. The facility must have enough insulation between the mains (or auxiliary) voltage and the KNX bus or the wires of other accessories, in case of being installed.
- Once the device is installed (in the panel or box), it must not be accessible from outside.
- Keep the device away from water (condensation over the device included) and do not cover it with clothes, paper or any other material while in use.
- The WEEE logo means that this device contains electronic parts and it must be properly disposed of by following the instructions at <https://www.zennio.com/en/legal/weee-regulation>.
- This device contains software subject to specific licences. For details, please refer to <http://zennio.com/licenses>.